



GOVT OF WEST BENGAL
PUBLIC HEALTH ENGINEERING DIRECTORATE
OFFICE OF THE EXECUTIVE ENGINEER, COOCH BEHAR DIVISION
DEBIBARI, LICHUTALA, COOCH BEHAR

Memo No. :378...../CD

Date :02.3.26.....

To
✓ The PRINCIPAL
BINA MOHIT MEMORIAL SCHOOL,
CBSE Affiliation No.- 2430164
Mahish Bathan,
Cooch Behar – 736179

Sub : Chemical, Physical and Bacteriological analysis report of 01 (one) no.
water sample mentioned in the test result.

With reference to the above enclosed herewith please find the chemical, physical and bacteriological analysis report for 01(one) no. of water sample of the said location tested. Water sample test result is enclosed.

Encl : As stated


Executive Engineer
Cooch Behar Division
PHE Dte

Memo No. :/CD

Date :

Copy forwarded to :-

- 1) The Assistant Engineer, RWS, Cooch Behar Sub Division, PHE Dte
- 2) Office Copy

Executive Engineer
Cooch Behar Division
PHE Dte

PUBLIC HEALTH ENGINEERING DIRECTORATE
OFFICE OF THE EXECUTIVE ENGINEER, COOCH BEHAR DIVISION
DEBIBARI, LICHUTALA, COOCH BEHAR
COOCH BEHAR DISTRICT WATER TESTING LABORATORY, COOCH BEHAR
TEST REPORT OF WATER QUALITY (Chemical, Physical & Bacteriological) ID : 1453/02/26/SL No.32

Date of Collection : 26.02.2026

Date of Test : 26.02.2026 to 27.02.2026

Sl. No.	Location Description	Type of Water Source	Chemical and Physical Parameter									Bacteriological Parameter		Remarks
			Iron	Total Hardness	Mn	pH	Calcium	Magnesium	TDS	Turbidity	Chloride	Total Coliform	Faecal Coliform	
			(mg/lit)	(mg/lit)	(mg/lit)		(mg/lit)	(mg/lit)	(mg/lit)	(NTU)	(mg/lit)	(MFT)	(MFT)	
1	BINA MOHIT MEMORIAL SCHOOL, Mahish Bathan, Cooch Behar. Ref No.- BMMS/F-21/2025-26/2234, Date-20.02.2026, GRN-192024260489745248	Ground Water	0.07	60.81	0.02	7.02	14.59	5.84	72.8	0.21	5.62	0	0	NORMAL
Desirable limit for drinking water as per IS 10500 : 2012			1	200	0.1	6.5-8.5	75	30	500	1	250	0	0	
Permissible limit for drinking water as per IS 10500 : 2012 & D.O.WQ - 11021/7/2016-WQ			1	600	0.3	6.5-8.5	200	100	2000	5	1000	0	0	

Signature of Chemist/Bacteriologist


 Assistant Engineer
 RWS, Cooch Behar Sub - Division
 PHE Dte